

Important: Read all instructions prior to installation.

LED Retrofit High Bay Lamp

Safety and Notes

- Product should be installed by certified electrician in accordance with applicable national, state, and local building and electrical codes.
- To reduce the risk of electric shock, ensure that the main power source and circuit breakers are switched off before performing any installation or wiring procedures.
- Avoid looking directly into the lamp when illuminated.
- Designed for direct wire installation only, bypassing existing ballasts where applicable.
- When removing existing ballast reference FIG 1 for wiring. Apply the provided label, after installation, in any visible location on the fixture.
- Make sure to attach safety cable to secure location during installation.



Specifications

Model	HBR2-50K100C-EX39	HBR2-50K120C-EX39	HBR2-50K150C-EX39
Operating Voltage	120–277 VAC		
Wattage	100 W	120 W	150 W
HID Equivalency	250 W	400 W	600 W
Base Type	EX39		
Operating Temperature	-4°–113° F (-20°–45° C)		
Dimmable	No		

Retrofit Installation Instructions

This lamp should be used to replace existing incandescent, HPS/HID, and CFL lamps with an EX39 or E39 base only. If used in accordance with these instructions on a UL or ETL listed light, the light will retain its original certification.

Caution: When removing ballast, this product must be installed in accordance with the applicable installation code by a qualified electrician familiar with the construction and operation of the product and the hazards involved.

Retrofit Modification Label

Label containing the following caution needs to be placed onto the original fixture and in a location that is visible during maintenance.

Caution Risk of Injury or Damage:


This luminaire has been modified to operate LED lamps. Do not attempt to install or operate incandescent, HPS/HID, or CFL lamps in this luminaire.



Important: Read all instructions prior to installation.

LED Retrofit High Bay Lamp

Retrofit Wiring Diagram



Dimensional Diagram

